

Notice of Testing and Classification

COSTUMER	Sunithon Energy Kft.
ADRESS	1139 Szekszardi utc 9 Budapest, Hungary
ASSOCIATED REPORT No.	055158-001-2 055158-002-2 055158-003-2 055158-004-2

SAMPLE TESTED

Laminated glass made of two sheets of toughened glass of 6 mm, two layers of PVB of 0.76 mm and photovoltaic silicon float glass of 3.2 mm referenced as follows:

«636-BN-»

CONDUCTED TEST

The tests requested are that of

- **Impact resistance** in accordance with UNE-EN 12600:2003
- **Manual attack** in accordance with UNE-EN 356:2001
- **High temperature** in accordance with UNE-EN ISO 12543-4:2011
- **Humidity** in accordance with UNE-EN ISO 12543-4:2011

RESULT

Impact resistance
Manual attack
High temperature
Humidity

Class 1B1
Class P4A
SATISFACTORY
SATISFACTORY

Test dates	21.03.2024 – 19.04.2024
Date issued	20.04.2024

These results are the summary of the data included in the Test Report identified above as the associated test Report No.

The results obtained in these tests only refer to the sample(s) analysed at this centre on the date shown, and do not involve a sample referring to production quality.



 Signed: Susana Santamaría
 Technical Consultant
 Construction - Services